



2022 Annual Report

RM of Stanley Public Water System

(Red River Regional)

System Code: 218.25

Reinfeld, Schanzenfeld, Blumstein



**Name of the public water system:
RM of Stanley Public Water System**

**Name of the legal owner:
Rural Municipality of Stanley**

**Water Source:
Red River Regional Public Water System- Pembina Valley Water CO-OP**

Emergency Contact Information:

Call the RM of Stanley Office: 204-325-4101

In the event of an emergency outside of regular business hours you will be transferred to an on-call operator.

Email: info@rmofstanley.ca

Contact Persons:

Ken Thiessen	– Public Works Supervisor	-204-362-7335
Dave Rempel	– Utilities Manager	-204-362-2361
Dustin Dyck	– Utility Operator	-204-362-8176
Melanie Walker	– Utilities – (Admin)	-204-325-4101

Introduction:

This RM of Stanley water system has three different local systems amalgamated into one. The Reinfeld, Schanzenfeld, Blumstein and surrounding areas are represented within the same license. The Schanzenfeld and Reinfeld utility systems began receiving treated water from the Pembina Valley Water Co-op in 2002 and continues to receive water from the PVWC. Water is provided to the un-incorporated villages of Schanzenfeld, Chortitz, Friedensruh, Reinfeld and various other rural properties in the general area. The system continues to expand in order to service continued development being experienced in the area. A 300,000L reservoir expansion was completed in the fall of 2010 in both Schanzenfeld and Reinfeld to accommodate the increase in water connections. This brought the total reservoir storage at each location up to 500,000L.


Description of the Water System:

Source

The RM of Stanley Public Water System purchases water from the Pembina Valley Water Co-op which draws the water from the Red River at the Letellier Treatment facility in Letellier MB. The Pembina Valley Water Co-op is a wholesaler of water which it sells to the RM of Stanley. The treated water is pumped west along PVWC main lines up to the Reinfeld reservoir and then to the Winkler south booster station where it is pumped into the Schanzenfeld reservoir. It is then distributed to the final consumers.

Treatment

The water is treated at the Pembina Valley Water Co-op Treatment Plant in Letellier. A detailed description of their treatment process can be obtained directly from the PVWC at 204-324-1931 or email: pvwc@mts.net.



Upon entering Stanley's reservoirs, the treated water is re-chlorinated with sodium hypochlorite to ensure that required disinfection residuals are maintained throughout the system. Treated water is then pumped throughout the distribution system to the final consumer.

Distribution

The distribution system is a network of underground pipes which delivers the water to the end consumers. When the water leaves the reservoirs, it is pumped through various sizes of PVC pipe (2"-6"). Most service line sizes range from ¾" – 1 ½". The total distribution network is approximately 80 kms long. Generators have been installed at all of Stanley's water stations. This allows us to maintain constant system pressure during power outages. Gate valves are installed throughout the system to be able to isolate sections of line for emergency or maintenance purposes. Curbstops are installed on each service line to be able to shut off residential lines in case of emergencies. *Customers should take care not to damage valves.*

Storage Reservoirs

In this system we have 1 (one) 200,000 litre reinforced concrete 2-cell reservoir and 1 (one) 300,000 litre reinforced concrete 3-cell reservoir north of Schanzenfeld and 1 (one) 200,000 litre reinforced concrete 2-cell reservoir and 1 (one) 300,000 litre reinforced concrete 3-cell reservoir in Reinfeld. With a capacity of 500,000 litres each, these reservoirs act as a buffer to alleviate peak demands and maintain adequate pressure on the system. At current demands, the reservoirs hold approximately 1 day of storage. In addition to our current storage, we are building a new 4-million-liter reservoir close to the BTH hospital (Blumstein System).



Number of connections, population served, & types of water users

At the end of December 2022, the Stanley Water system had 1,105 service connections and billed out an average of 14,250,000 gallons of water per quarter and served an estimated population of 4,420. These systems service 4 Elementary Schools, 7 Churches and a number of large Agricultural & Commercial users while the majority of connections are for residential properties. Stanley also supplies water to the Boundary Trails Hospital. Each connection is equipped with a water meter to measure water volumes for monitoring, administrative, and billing purposes. Water meters are read quarterly by the customer.

Classification/Certification

The Stanley Public Water System (RRR) is classified as a Class Two (2) Distribution System. Classification/certification is regulated under Manitoba Conservation's Water and Wastewater Facility Operators Regulation under *The Environment Act*. Stanley has 2 full-time operators and one part-time. All are certified.

The operators continually participate in educational seminars to keep up their training.

Equipment:

Each pumphouse is equipped with one – 2 horsepower variable speed pump and three - 5 horsepower variable speed pumps with a combined pumping rate of 225 Gallons per minute. All water lines on the system are made of PVC and high-density polyethylene materials. The line pressure along the corridor from Winkler to Morden (Blumstein) is supplied by PVWC.



How is the Utility Operator notified in cases of emergencies?

The water pumphouses uses electronic tele-metering equipment as a means for monitoring operations. This system notifies the utility operator by way of telephone in case of any problems regarding pressures, water levels, power failures, temperatures, and noise levels. This equipment also allows the utility operator to monitor several components of the reservoir operations while off-site through the use of a telephone. The RM of Stanley Utility Operator is notified by telephone in case of any emergency or discrepancy with the system.

In 2020 the Schanzenfeld and Reinfeld systems were upgraded to an electronic monitoring system (PLC) that allows the operators to monitor live pressures, reservoir levels, and flows off-site. This also allows them to diagnose problems and help them trend the operations of the pumphouses.

A Utility Operator is on call 24 hours/day. In case of an emergency call the RM of Stanley office where you will be transferred to an on-call operator.

Emergency #: 1-204-325-4101



Water Quality Standards

There are certain water quality standards that are adhered to for the safety of the public. Below is a list of the health standards that are followed on the Stanley Public Water System. When there is a failure to meet these standards, immediate corrective actions are taken.

Parameter	Quality Standard
Total Coliform	Less than one total coliform bacteria detectable per 100 mL in all distributed water
<i>E. coli</i>	Less than one <i>E. coli</i> bacteria detectable per 100 mL in all distributed water
Chlorine Residual	A free chlorine residual of at least 0.1 mg/L at all times at any point in the water distribution system
Total Trihalomethanes (THMs)	Less than or equal to 0.10 mg/L as locational annual average of quarterly samples
Total Haloacetic Acids (HAAs)	Less than or equal to 80 ug/L (micrograms/liter) as locational annual average of quarterly samples
Lead	Less than or equal to 0.01 mg/L in the water distribution system

Water samples are retrieved, tested, and recorded onsite for chlorine levels each day. There are two chlorine standards, one for leaving the reservoir and one for within the distribution system. The minimum free chlorine standards are 0.5 mg/L leaving the reservoir and 0.1mg/L throughout the distribution system.

These charts outline the 2022 Chlorination results leaving the Schanzenfeld and Reinfeld reservoirs as reported by the Utility Operator.

2022 Schanzenfeld

Month	# of Samples	
	Taken	Compliance
January	30	100%
February	28	100%
March	31	100%
April	30	100%
May	31	100%
June	30	100%
July	31	100%
August	31	100%
September	30	100%
October	31	100%
November	30	100%
December	31	100%

2022 Reinfeld

Month	# of Samples	
	Taken	Compliance
January	31	100%
February	28	100%
March	31	100%
April	30	100%
May	31	100%
June	30	100%
July	31	100%
August	31	100%
September	30	100%
October	31	100%
November	30	100%
December	31	100%

The following outlines the 2022 test results as submitted by the Operator to ALS Environmental for analysis. Samples are submitted every two weeks from the incoming treated water (PVWC), the outgoing treated water from the reservoir, and a distribution system location. The distribution chlorine residuals are measured at the same time and location as the bacteriological distribution samples and are included in the chart below.

Blumstein

This system runs off PVWC's line between Winkler and Morden. The chlorine residual is dependent on PVWC chlorination.

Coliforms & E. coli - Outflow Treated

Date	In Distribution System					
	Coliforms MPN/100ml	E. coli MPN/100ml	Compliant	Chlorine Free mg/L	Chlorine Total mg/L	Compliant
Jan 17/22	0	0	Yes	0.13	0.55	Yes
Feb.2/22	0	0	Yes	0.13	0.62	Yes
Feb 14/22	0	0	N/A	N/A	N/A	N/A
Mar 1/22	0	0	Yes	0.40	0.73	Yes
Mar 15/22	0	0	Yes	0.84	1.13	Yes
Mar 29/22	0	0	Yes	0.77	1.19	Yes
Apr 12/22	0	0	Yes	0.63	0.96	Yes
Apr 26/22	0	0	Yes	0.59	0.91	Yes
May 10/22	0	0	Yes	0.52	0.87	Yes
May 26/22	0	0	Yes	1.00	1.32	Yes
May 25/21	0	0	Yes	0.63	0.86	Yes
June 9/22	0	0	Yes	0.30	0.56	Yes
June 23/22	0	0	Yes	0.68	0.92	Yes
July 4/22	0	0	Yes	0.77	0.83	Yes
July 20/22	0	0	Yes	0.51	0.72	Yes
Aug 5/22	0	0	Yes	0.56	0.82	Yes
Aug 16/22	0	0	Yes	0.36	0.63	Yes
Aug 31/22	0	0	Yes	0.38	0.66	Yes
Sept 13/22	0	0	Yes	0.28	0.56	Yes
Sept 26/22	0	0	Yes	0.31	0.47	Yes
Oct 12/22	0	0	Yes	0.56	0.82	Yes
Oct 28/22	0	0	Yes	0.18	0.46	Yes
Nov 8/22	0	0	Yes	0.42	0.61	Yes
Nov 24/22	0	0	Yes	0.06	0.35	Yes
Dec 6/22	0	0	Yes	0.27	0.46	Yes
Dec 22/22	0	0	Yes	0.30	0.57	Yes

Reinfeld Distribution

Coliforms & E. coli – Distribution system

Date

In Distribution System

	Coliforms	E. coli		Chlorine Free	Chlorine Total	Compliant
	MPN/100 ml	MPN/100ml	Compliant	mg/L	mg/L	
Jan 17/22	0	0	Yes	1.06	1.56	Yes
Feb 2/22	0	0	Yes	1.06	1.58	Yes
Feb 10/22	0	0	N/A	N/A	N/A	N/A
Mar 1/22	0	0	Yes	0.99	1.11	Yes
Mar 15/22	0	0	Yes	1.10	1.46	Yes
Mar 29/22	0	0	Yes	1.31	1.76	Yes
Apr 12/22	0	0	Yes	0.63	0.96	Yes
Apr 26/22	0	0	Yes	1.19	1.59	Yes
May 10/22	0	0	Yes	1.13	1.52	Yes
May 26/22	0	0	Yes	0.93	1.24	Yes
June 9/22	0	0	Yes	1.13	1.46	Yes
June 23/22	0	0	Yes	1.17	1.32	Yes
July 4/22	0	0	Yes	0.81	0.99	Yes
July 20/22	0	0	Yes	0.61	0.84	Yes
Aug 5/22	0	0	Yes	1.26	1.31	Yes
Aug 16/22	0	0	Yes	1.04	1.44	Yes
Aug 31/22	0	0	Yes	1.13	1.54	Yes
Sept 13/22	0	0	Yes	1.16	1.56	Yes
Sept 26/22	0	0	Yes	1.07	1.47	Yes
Oct.12/22	0	0	Yes	1.07	1.48	Yes
Oct 28/22	0	0	Yes	0.94	1.32	Yes
Nov.8/22	0	0	Yes	1.01	1.45	Yes
Nov.24 /22	0	0	Yes	0.73	0.91	Yes
Dec.6 /22	0	0	Yes	0.96	1.13	Yes
Dec.22 /22	0	0	Yes	0.93	1.27	Yes

Schanzenfeld Distribution

Coliforms & E. coli - Outflow Treated

Date	Coliforms			In Distribution System		
	MPN/100ml	E. coli MPN/100ml	Compliant	Chlorine Free mg/L	Chlorine Total mg/L	Compliant
Jan 17/22	0	0	Yes	0.91	1.58	Yes
Feb 2/22	0	0	Yes	0.99	1.56	Yes
Feb 10/22	0	0	N/A	N/A	N/A	N/A
Mar 1/22	0	0	Yes	0.86	1.51	Yes
Mar 15/22	0	0	Yes	1.21	1.65	Yes
Mar 29/22	0	0	Yes	1.36	1.78	Yes
Apr 12/22	0	0	Yes	0.96	1.31	Yes
Apr 26/22	0	0	Yes	1.09	1.36	Yes
May 10/22	0	0	Yes	1.06	1.56	Yes
May 30/22	0	0	Yes	0.99	1.26	Yes
June 9/22	0	0	Yes	1.05	1.31	Yes
June 23/22	0	0	Yes	0.96	1.27	Yes
July 4/22	0	0	Yes	0.96	1.23	Yes
July 20/22	0	0	Yes	0.83	0.99	Yes
Aug 5/22	0	0	Yes	0.82	1.14	Yes
Aug 16/22	0	0	Yes	1.15	1.46	Yes
Aug 31/22	0	0	Yes	0.88	1.14	Yes
Sept 13/22	0	0	Yes	1.04	1.41	Yes
Sept 26/22	0	0	Yes	1.09	1.53	Yes
Oct.12/22	0	0	Yes	0.98	1.37	Yes
Oct 28/22	0	0	Yes	0.97	1.32	Yes
Nov.8/22	0	0	Yes	0.93	1.38	Yes
Nov.24 /22	0	0	Yes	0.92	1.30	Yes
Dec.6 /22	0	0	Yes	1.03	1.30	Yes
Dec.22 /22	0	0	Yes	0.71	0.93	Yes

At any time when the free chlorine residual requirement is not met immediate action is taken by the Operator to adjust amounts of chlorine being added to ensure future compliance.

THM's & HAA's

Every two years, quarterly testing is done for THM's & HAA's as required by the Office of Drinking Water. Reporting years are 2022, 2024 and so on.

Trihalomethanes (THM's) are formed when chlorine reacts with naturally occurring organic matter in the water. Studies have shown a link between high levels of THM's and cancer. For that reason, the province has set a health-based standard for THM's of *0.1mg/L*. THM's were tested in the Schanzenfeld Public Water System in 2022 producing the following results. Compliance with provincial standards is dependent on the effectiveness of the treatment process.

THM's

Feb. 2022	0.195 mg/L
June 2022	0.0920 mg/L
Oct. 2022	0.194 mg/L
Nov. 2022	0.187 mg/L

Haloacetic acids (HAAs) are a common undesirable by-product of drinking water chlorination. HAAs can be formed by chlorination, ozonation or chloramination of water with formation promoted by slightly acidic water, high organic matter content and elevated temperature. Chlorine from the water disinfection process can react with organic matter and small amounts of bromide present in water to produce various HAAs. The MAC (maximum acceptable concentration) for HAA's is 80 ug/L (micrograms/liter). Compliance with provincial standards is dependent on the effectiveness of the treatment process. Testing was done in Reinfeld producing the following results.

HAA's

Feb. 2022	52.0 ug/L
June 2022	47.3 ug/L
Oct. 2022	95 ug/L
Nov. 2022	82.7 ug/L

Water system incidents.

8 water breaks were recorded for 2022.

Drinking water safety orders on system.

None

Boil water advisories issued.

There were a few boil water advisories on the Red River Regional system in 2022. Boil Water advisories are issued when the line pressure drops below 20 psi.

Warnings issued or charges laid in accordance with Drinking Water Safety Act.

None.

Annual Audit by the Office of Drinking Water

A copy of the annual audit done by the Office of Drinking water is available by request through the RM of Stanley.

Permits and Licenses

All operator licenses are valid and up to date. A third part time fully licensed operator has been added as a contract operator. System permits are also all in place as required. This information is posted at every site and available at the RM of Stanley Office.

Major Expenses Incurred.

The Schanzenfeld reservoir was cleaned in 2022 for about \$9,500.

Anticipated Expenses

A new 4,000,000L reservoir and pumping station is being built along the main corridor. This station will provide water to the hospital and to the main corridor. It can also back feed to Reinfeld and Schanzenfeld in emergency situations

Future system expansion.

None

RM of Stanley Notifications

[Stay Connected! Register Today!](#)

We are pleased to announce the launch of Connect Stanley, our new communication system. Along with a new website and mobile apps, we will keep you alerted on road closures, other public works and transportation notices, burning restrictions, water service disruptions and emergency alert messages from Canada's national emergency alerting system (Alert Ready). You decide how you want to receive information, whether it be by text messages, phone calls, e-mails or any combination you choose.

Register with us never miss out on the latest news on road closures, other public works and transportation notices, burning restrictions, water service disruptions and emergency alert messages from Canada's national emergency alerting system (Alert Ready).

A free copy of the 2022 Annual Report can be obtained at the RM office.