



2020 Annual Report

RM of Stanley Public Water System

(Red River Regional)

System Code: 218.25

Reinfeld, Schanzenfeld, Blumstein



**Name of the public water system:
Red River Regional Public Water System**

**Name of the legal owner:
Rural Municipality of Stanley**

**Water Source:
Red River - Pembina Valley Water CO-OP**

Emergency Contact Information:

Call the RM of Stanley Office: 204-325-4101

In the event of an emergency outside of regular business hours you will be transferred to an on-call operator.

**Office Fax: 204-325-4008
Email: info@rmofstanley.ca**

Name of Contact Persons:

**Ken Thiessen – Public Works Supervisor
Dave Rempel – Utilities Manager
Dustin Dyck – Utility Operator
Melanie Walker – Utilities – (Administrative)**

Introduction:

This RM of Stanley Public Water System (Red River Regional) has three different local systems amalgamated into one. The Reinfeld, Schanzenfeld, Blumstein and surrounding areas are represented within the same license. The Schanzenfeld Water System began receiving treated water from the Pembina Valley Water Co-op in August of 2002 and continues to receive water from the PVWC. The existing reservoir, pump house and mainline running from the reservoir south to Schanzenfeld was constructed in 1997. Water is provided to the un-incorporated villages of Schanzenfeld, Chortitz, Friedensruh, Reinfeld and various other rural properties in the general area. The system continues to expand to service continued development being experienced in the area. A 300,000L reservoir expansion was completed in the fall of 2010 in both Schanzenfeld and Reinfeld to accommodate the increase in water connections bringing the total reservoir storage at each location up to 500,000L.


Description of the Water System:

Source

This RM of Stanley Public Water System purchases water from the Pembina Valley Water Co-op which draws the water from the Red River at the Letellier Treatment facility in Letellier MB. The Pembina Valley Water Co-op is a wholesaler of water which it sells to the RM of Stanley. The treated water is pumped west along PVWC main lines up to the Reinfeld reservoir and then to the Winkler south booster station where it is pumped into the Schanzenfeld reservoir. It is then distributed to the final consumers.

Treatment

The water is treated at the Pembina Valley Water Co-op Treatment Plant in Letellier. A detailed description of their treatment process can be obtained directly from the PVWC at 204-324-1931 or email: pvwc@mts.net.



Upon entering Stanley's reservoirs, the treated water is re-chlorinated with sodium hypochlorite to ensure that required disinfection residuals are maintained throughout the system. The treatment systems in the Reinfeld and Schanzenfeld pumphouses were upgraded in 2019 with the purchase of 2 peristaltic chlorine pumps. Treated water is then pumped throughout the distribution system to the final consumer.

Distribution

The distribution system is a network of underground pipes which delivers the water to the end consumers. When the water leaves the reservoirs, it is pumped through various sizes of PVC pipe (2"-6"). Most service line sizes range from $\frac{3}{4}$ " - 1 $\frac{1}{2}$ ". The total distribution network is approximately 47 miles long. Generators were installed at both Reinfeld and Schanzenfeld pumphouses in 2017 to maintain constant system pressure during power outages. Gate valves are installed throughout the system to be able to isolate sections of line for emergency or maintenance purposes. Curbstops are installed on each service line to be able to shut off residential lines in case of emergencies. **Customers should take care not to damage valves.**

Storage Reservoirs

In this system we have 1 (one) 200,000 litre reinforced concrete 2-cell reservoir and 1 (one) 300,000 litre reinforced concrete 3-cell reservoir north of Schanzenfeld and 1 (one) 200,000 litre reinforced concrete 2-cell reservoir and 1 (one) 300,000 litre reinforced concrete 3-cell reservoir in Reinfeld. With a capacity of 500,000 litres each, these reservoirs act as a buffer to alleviate peak demands and maintain adequate pressure on the system. At current demands, the reservoirs hold approximately 1.2 days of storage. The Reinfeld reservoir was cleaned in 2020 with the Schanzenfeld reservoir scheduled for a 2021 cleaning. In addition to our current storage, we are in the planning stages of building a new 4 million liter reservoir close to the BTH hospital (Blumstein System).



Number of connections, population served, & types of water users

As of December 2020, the Stanley Water system had 1,087 service connections and billed out an average of 15,287,694 gallons of water per quarter and served an estimated population of 4,348. These systems service 4 Elementary Schools, 7 Churches and a number of large Agricultural & Commercial users while the majority of connections are for residential properties. Stanley also supplies water to Boundary Trails Hospital. Each connection is equipped with a water meter to measure water volumes for monitoring, administrative, and billing purposes. Water meters are read quarterly by the customer.

Classification/Certification

The Stanley Public Water System (RRR) is classified as a Class Two (2) Distribution System. Classification/certification is regulated under Manitoba Conservation's Water and Wastewater Facility Operators Regulation under *The Environment Act*.

Equipment:

Each pumphouse houses one – 2 horsepower variable speed pump and three - 5 horsepower variable speed pumps with a combined pumping rate of 225 Gallons per minute. All water lines on the system are made of PVC and high-density polyethylene materials. The line pressure along the corridor from Winkler to Morden is supplied by PVWC.



How is the Utility Operator notified in cases of emergencies?

The water pumphouses uses electronic tele-metering equipment as a means for monitoring operations. This system notifies the utility operator by way of telephone in case of any problems regarding pressures, water levels, power failures, temperatures, and noise levels. This equipment also allows the utility operator to monitor several components of the reservoir operations while off-site through the use of a telephone. The RM of Stanley Utility Operator is notified by telephone in case of any emergency or discrepancy with the system.

In 2020 the Schanzenfeld and Reinfeld systems were upgraded to an electronic monitoring system that allows the operators to monitor live pressures, reservoir levels, and flows off-site. This also allows them to diagnose problems and help them trend the operations of the pumphouses.

A Utility Operator is on call 24 hours/day. In case of an emergency call the RM of Stanley office where you will be transferred to an on-call operator.

Emergency #: 1-204-325-4101



Water Quality Standards

There are certain water quality standards that are adhered to for the safety of the public. Below is a list of the health standards that are followed on the Stanley Public Water System. When there is a failure to meet these standards immediate corrective actions are taken.

| Parameter | Quality Standard |
|-------------------------------|----------------------------------------------------------------------------------------------------------|
| Total Coliform | Less than one total coliform bacteria detectable per 100 mL in all distributed water |
| <i>E. coli</i> | Less than one <i>E. coli</i> bacteria detectable per 100 mL in all distributed water |
| Chlorine Residual | A free chlorine residual of at least 0.1 mg/L at all times at any point in the water distribution system |
| Total Trihalomethanes (THMs) | Less than or equal to 0.10 mg/L as locational annual average of quarterly samples |
| Total Haloacetic Acids (HAAs) | Less than or equal to 0.08 mg/L as locational annual average of quarterly samples |
| Lead | Less than or equal to 0.01 mg/L in the water distribution system |

Water samples are retrieved, tested, and recorded onsite for chlorine levels each day. There are two chlorine standards, one for leaving the reservoir and one for within the distribution system. The minimum free chlorine standards are 0.5 mg/L leaving the reservoir and 0.1mg/L throughout the distribution system.

These charts outline the 2020 Chlorination results leaving the Schanzenfeld and Reinfeld reservoirs as reported by the Utility Operator.

2020 Schanzenfeld

| Month | # of Samples | |
|-----------|--------------|------------|
| | Taken | Compliance |
| January | 30 | 100% |
| February | 28 | 100% |
| March | 31 | 100% |
| April | 30 | 100% |
| May | 31 | 100% |
| June | 30 | 100% |
| July | 31 | 100% |
| August | 31 | 100% |
| September | 30 | 100% |
| October | 31 | 100% |
| November | 30 | 100% |
| December | 31 | 100% |

2020 Reinfeld

| Month | # of Samples | |
|-----------|--------------|------------|
| | Taken | Compliance |
| January | 31 | 100% |
| February | 28 | 100% |
| March | 31 | 100% |
| April | 30 | 100% |
| May | 31 | 100% |
| June | 30 | 100% |
| July | 31 | 100% |
| August | 31 | 100% |
| September | 30 | 100% |
| October | 31 | 100% |
| November | 30 | 100% |
| December | 31 | 100% |

The following outlines the 2020 test results as submitted by the Operator to ALS Environmental for analysis. Samples are submitted every two weeks from the incoming treated water (PVWC), the outgoing treated water from the reservoir, and a distribution system location. The distribution chlorine residuals are measured at the same time and location as the bacteriological distribution samples and are included in the chart below.

Blumstein

This system runs off PVWC line between Winkler and Morden. The chlorine residual is dependent on PVWC chlorination.

Coliforms & E. coli - Outflow Treated

| Date | Coliforms & E. coli - Outflow Treated | | | In Distribution System | | |
|------------|---------------------------------------|----------------------|-----------|------------------------|------------------------|-----------|
| | Coliforms MPN/100ml | E. coli MPN/100ml | Compliant | Chlorine Free mg/L | Chlorine Total mg/L | Compliant |
| Jan 9/20 | 0 | 0 | Yes | 1.00 | 1.48 | Yes |
| Jan 23/20 | 0 | 0 | Yes | 1.07 | 1.50 | Yes |
| Feb 6/20 | 0 | 0 | Yes | 1.00 | 1.21 | Yes |
| Feb 21/20 | 0 | 0 | Yes | 0.95 | 1.46 | Yes |
| Mar 6/20 | 0 | 0 | Yes | 0.76 | 1.07 | Yes |
| Mar 19/20 | 0 | 0 | Yes | 1.50 | 1.88 | Yes |
| Apr 2/20 | 0 | 0 | Yes | 0.98 | 1.13 | Yes |
| Apr 17/20 | 0 | 0 | Yes | 0.55 | 0.92 | Yes |
| Apr 30/20 | 0 | 0 | Yes | 0.84 | 1.11 | Yes |
| May 14/20 | 0 | 0 | Yes | 0.42 | 0.68 | Yes |
| May 28/20 | 0 | 0 | Yes | 0.96 | 1.28 | Yes |
| June 11/20 | 0 | 0 | Yes | 0.51 | 0.56 | Yes |
| June 25/20 | 0 | 0 | Yes | 0.76 | 1.09 | Yes |
| July 9/20 | 0 | 0 | Yes | 0.92 | 1.10 | Yes |
| July 22/20 | 0 | 0 | Yes | 0.37 | 0.70 | Yes |
| Aug 7/20 | 0 | 0 | Yes | 0.45 | 0.86 | Yes |
| Aug 24/20 | 0 | 0 | Yes | 0.41 | 0.77 | Yes |
| Sept 2/20 | 0 | 0 | Yes | 0.57 | 0.91 | Yes |
| Sept 17/20 | 0 | 0 | Yes | 0.37 | 0.68 | Yes |
| Sept 30/20 | 0 | 0 | Yes | 0.76 | 0.98 | Yes |
| Oct 15/20 | 0 | 0 | Yes | 0.36 | 0.86 | Yes |
| Oct 28/20 | 0 | 0 | Yes | 0.36 | 0.72 | Yes |
| Nov 12/20 | 0 | 0 | Yes | 0.51 | 1.09 | Yes |
| Nov 25/20 | 0 | 0 | Yes | 0.64 | 0.98 | Yes |
| Dec 10/20 | 0 | 0 | Yes | 0.73 | 1.01 | Yes |
| Dec 24/20 | 0 | 0 | Yes | 0.55 | 1.03 | Yes |

Reinfeld Distribution

Coliforms & E. coli – Distribution system

Date

In Distribution System

| Date | Colifor | | | In Distribution System | | |
|------------|---------------------|----------------------|-----------|------------------------|------------------------|-----------|
| | ms MPN/ 100ml | E. coli MPN/100ml | Compliant | Chlorine Free mg/L | Chlorine Total mg/L | Compliant |
| Jan 9/20 | 0 | 0 | Yes | 1.58 | 2.13 | Yes |
| Jan 23/20 | 0 | 0 | Yes | 1.33 | 1.84 | Yes |
| Feb 6/20 | 0 | 0 | Yes | 0.96 | 1.43 | Yes |
| Feb 21/20 | 0 | 0 | Yes | 1.36 | 1.89 | Yes |
| Mar 6/20 | 0 | 0 | Yes | 0.70 | 1.09 | Yes |
| Mar 19/20 | 0 | 0 | Yes | 1.54 | 1.87 | Yes |
| Apr 2/20 | 0 | 0 | Yes | 0.84 | 1.10 | Yes |
| Apr 17/20 | 0 | 0 | Yes | 0.86 | 0.99 | Yes |
| Apr 30/20 | 0 | 0 | Yes | 1.21 | 1.56 | Yes |
| May 14/20 | 0 | 0 | Yes | 0.85 | 0.99 | Yes |
| May 28/20 | 0 | 0 | Yes | 0.91 | 1.11 | Yes |
| June 11/20 | 0 | 0 | Yes | 0.86 | 1.20 | Yes |
| June 25/20 | 0 | 0 | Yes | 1.14 | 1.36 | Yes |
| July 9/20 | 0 | 0 | Yes | 1.00 | 1.37 | Yes |
| July 22/20 | 0 | 0 | Yes | 0.78 | 1.20 | Yes |
| Aug 7/20 | 0 | 0 | Yes | 0.75 | 1.11 | Yes |
| Aug 24/20 | 0 | 0 | Yes | 0.78 | 1.00 | Yes |
| Sept 2/20 | 0 | 0 | Yes | 1.02 | 1.39 | Yes |
| Sept 17/20 | 0 | 0 | Yes | 1.01 | 1.26 | Yes |
| Sept 30/20 | 0 | 0 | Yes | 0.99 | 1.32 | Yes |
| Oct 15/20 | 0 | 0 | Yes | 0.89 | 1.14 | Yes |
| Oct 28/20 | 0 | 0 | Yes | 1.01 | 1.28 | Yes |
| Nov 12/20 | 0 | 0 | Yes | 1.31 | 1.62 | Yes |
| Nov 25/20 | 0 | 0 | Yes | 1.26 | 1.48 | Yes |
| Dec 10/20 | 0 | 0 | Yes | 1.21 | 1.61 | Yes |
| Dec 24/20 | 0 | 0 | Yes | 1.08 | 1.43 | Yes |

Schanzenfeld Distribution
Coliforms & E. coli - Outflow Treated

| Date | In Distribution System | | | | | |
|------------|------------------------|----------------------|-----------|-----------------------|------------------------|-----------|
| | Coliforms MPN/100ml | E. coli MPN/100ml | Compliant | Chlorine Free mg/L | Chlorine Total mg/L | Compliant |
| Jan 9/20 | 0 | 0 | Yes | 1.42 | 1.82 | Yes |
| Jan 23/20 | 0 | 0 | Yes | 1.26 | 1.56 | Yes |
| Feb 6/20 | 0 | 0 | Yes | 0.88 | 1.11 | Yes |
| Feb 21/20 | 0 | 0 | Yes | 1.56 | 1.94 | Yes |
| Mar 6/20 | 0 | 0 | Yes | 0.90 | 1.28 | Yes |
| Mar 19/20 | 0 | 0 | Yes | 1.62 | 2.00 | Yes |
| Apr 2/20 | 0 | 0 | Yes | 0.98 | 1.28 | Yes |
| Apr 17/20 | 0 | 0 | Yes | 0.98 | 1.11 | Yes |
| Apr 30/20 | 0 | 0 | Yes | 1.59 | 1.89 | Yes |
| May 14/20 | 0 | 0 | Yes | 0.72 | 1.04 | Yes |
| May 28/20 | 0 | 0 | Yes | 0.76 | 0.91 | Yes |
| June 11/20 | 0 | 0 | Yes | 1.01 | 1.36 | Yes |
| June 25/20 | 0 | 0 | Yes | 1.06 | 1.28 | Yes |
| July 9/20 | 0 | 0 | Yes | 0.96 | 1.24 | Yes |
| July 22/20 | 0 | 0 | Yes | 0.95 | 1.21 | Yes |
| Aug 7/20 | 0 | 0 | Yes | 1.15 | 1.35 | Yes |
| Aug 24/20 | 0 | 0 | Yes | 0.41 | 0.58 | Yes |
| Sept 2/20 | 0 | 0 | Yes | 0.95 | 1.30 | Yes |
| Sept 17/20 | 0 | 0 | Yes | 0.85 | 1.30 | Yes |
| Sept 30/20 | 0 | 0 | Yes | 0.87 | 1.21 | Yes |
| Oct 15/20 | 0 | 0 | Yes | 0.96 | 1.29 | Yes |
| Oct 28/20 | 0 | 0 | Yes | 0.78 | 1.20 | Yes |
| Nov 12/20 | 0 | 0 | Yes | 1.23 | 1.50 | Yes |
| Nov 25/20 | 0 | 0 | Yes | 1.25 | 1.57 | Yes |
| Dec 10/20 | 0 | 0 | Yes | 1.23 | 1.43 | Yes |
| Dec 24/20 | 0 | 0 | Yes | 1.18 | 1.43 | Yes |

At any time when the free chlorine residual requirement is not met immediate action is taken by the Operator to adjust amounts of chlorine being added to ensure future compliance.

THM's & HAA's

Every two years, quarterly testing is done for THM's & HAA's as required by the Office of Drinking Water. Reporting years are 2020, 2022 and so on. These were the results from **2020**.

Trihalomethanes (THM's) are formed when chlorine reacts with naturally occurring organic matter in the water. Studies have shown a link between high levels of THM's and cancer. For that reason, the province has set a health-based standard for THM's of *0.1mg/L*. THM's were tested in the Schanzenfeld Public Water System in 2020 producing the following results. Compliance with provincial standards is dependent on the effectiveness of the treatment process.

THM's

| | |
|-----------|------------|
| Feb. 2020 | 0.135 mg/L |
| May 2020 | 0.104 mg/L |
| Aug. 2020 | 0.253 mg/L |
| Nov. 2020 | 0.189 mg/L |

Haloacetic acids (HAAs) are a common undesirable by-product of drinking water chlorination. HAAs can be formed by chlorination, ozonation or chloramination of water with formation promoted by slightly acidic water, high organic matter content and elevated temperature. Chlorine from the water disinfection process can react with organic matter and small amounts of bromide present in water to produce various HAAs. The MAC (maximum acceptable concentration) for HAA's is 80 ug/L (micrograms/liter). Compliance with provincial standards is dependent on the effectiveness of the treatment process. Testing was done in Reinfeld producing the following results.

HAA's

| | |
|-----------|-----------|
| Feb. 2020 | 62.2 ug/L |
| May 2020 | 48.3 ug/L |
| Aug. 2020 | 72.5 ug/L |
| Nov. 2020 | 69.4 ug/L |

Water system incidents.

4 water breaks were recorded for 2020. They were all repaired without incident.

Drinking water safety orders on system.

None

Boil water advisories issued.

Due to a water break, 1 maintenance boil water advisory was issued in November 2021 for a small portion of Blumstein. Sampling and testing came back negative.

2 maintenance boil water advisories were issued on the Stanley Public Water System. Both advisories were issued by the water provider (PVWC) as precautionary due to system maintenance. Advisories were communicated with the public and no negative consequences arose.

Warnings issued or charges laid in accordance with Drinking Water Safety Act.

None.

Annual Audit by the Office of Drinking Water

A copy of the annual audit done by the Office of Drinking water is available by request through the RM of Stanley.

Permits and Licenses

All operator licenses are valid and up to date. A third part time fully licensed operator has been added as a contracted employee. System permits are also all in place as required. This information is posted at every site and available at the RM of Stanley Office.

Major Expenses Incurred.

SCADA systems for Reinfeld and Schanzenfeld were installed at \$50,000. The Reinfeld reservoir was also cleaned out at a cost of \$10,000.

Future system expansion.

A 4 million litre reservoir build in the Winkler/Morden Corridor is in the planning stages and awaiting funding approvals. With the likelihood of low-pressure sewer coming into the Villages of Reinfeld and Schanzenfeld, we can expect those systems to double in the next 20 years from the new growth.

The possibility of the system being partially or fully fed from PVWC Morris plant is also the basis of an on-going project between the PVWC and MWSB.